


TECHNOTEST

DIRECTION "ASSESSMENT"

PRODUCTS CERTIFICATION BODY





CERTIFICATE

ENGLISH EDITION

No: 41-20-D

/PRODUCER/:

Issued to: 07.01.2020

Valid until: 06.01.2023

CERTIFICATE HOLDER

dormakaba Bulgaria Ltd

15, Heidelberg str., Druzhba 2 Distr., Sofia, 1582, Bulgaria

With this Certificate Direction "Assessment" certifies that:

PRODUCT: Revolving Door

TYPE: KTV 3 and KTV 4

MODELS: NS EXT; NS INT and NS EXT CH 100

TECHNICAL DATA:

Maximum/ Minimum Internal diameter (D) - 3800 mm/ 2000 mm

Dimensions: Clear passage height (PH) - 3000 mm/ 2200 mm;

Clear passage width (LW) - 2637 mm/940 mm.

Drum/drum wall: Frames and Roof Construction - Straight and curved aluminum special

profiles according to the product's technical documentation.

Night Shield, Internal Frames - Straight and curved aluminum special profiles according to the

and External: product's technical documentation. Suspension - 4 pieces of guide rollers, with retainer and limiter, on leading aluminum arches.

Infilling: Laminated arcuate glass with resistance class according to BDS EN 356: 2001 - P4A, or higher. Fixing in the profiles with silicone, production

Kömmerling GmbH, Germany.

Closing and Locking: From the inside. Multi-point lock, model GU- Secury DR, production of GU

GmbH, Germany. Cylinder, model pExtra production of dormakaba GmbH,

Germany.

Operation Shield: Manual,

Attack Side: The outside of the door

CONFORMS TO THE

BDS EN 1627:2011 - resistance burglary - class RC 2

REQUIREMENTS OF::

Applied scheme for certification:

BASIS FOR ISSUE: Test report No 10879/04.12.2019 according to standards BDS EN 1628:2011+A1:2016; BDS EN 1629:2011+A1:2016; BDS EN 1630:2011+A1:2016, issued by Test Laboratory of Department "Testings" - TECHNOTEST and *Evaluation of Technical Documentation of the product (Dossier № 51/2019).*

The issued certificate is valid for the specific product and does not apply to its subsequent production.

> Head of Direction "Assessment"

> > (Ilya Hristov)