



CERTIFICATE OF APPROVAL

No CF 5342

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

dormakaba UK Ltd

Wilbury Way, Hitchin, Hertfordshire SG4 0AB
Tel: 01462 477600 Fax: 01462 477601

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

**dormakaba SVP 2000, 4000,
5000 & 6000 Series Locks**

TECHNICAL SCHEDULE

**TS23 The Contribution of
Locks and Latches to The
Performance of Fire
Resisting Doorsets**

**TS 31 The Contribution of
Emergency Exit Devices,
Operated by a Lever Handle
or Push Pad, to the
Performance of Fire
Resisting Door Assemblies**

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager

Issued: 27th July 2015
Reissued: 8th December 2025
Valid to: 2nd June 2026



CERTIFICATE No CF 5342 DORMAKABA UK LTD

dormakaba SVP MORTICE LOCKSETS

1. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. The locks covered by this certificate are all have steel bolts, forends, cases and strikeplates. This approval relates to the following specific locks:

Reference	Description
SVP 2000	Emergency Escape Motor Lock
SVP 4000	Switch Monitored Emergency Escape Lock
SVP 5000	Emergency Escape Lock
SVP 6000	Switch Monitored Solenoid Emergency Escape Lock
C-Lever Compact	Electronic Handle/Reader
C-Lever Pro* (Narrow & Wide)	Electronic Handle/Reader

All lock models approved in with 20 mm and 24 mm width forend options.

The C-Lever Compact and C-Lever Pro are approved for use with the SVP 5000 Emergency Escape Locks only.

3. This approval relates to the use of the above locks/latches in contributing to the fire resistance performance of timber based doorsets, as defined in BS EN 1634-1 or BS 476: Part 22: 1987.
4. This approval relates to their use with the following door assemblies:-

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance of up to 60 minutes* (Code ITT).

***The use of the 'C-Lever Pro' handles/readers is restricted to a maximum of 30 minutes fire resistance.**

5. The locks are approved on the basis of:
 - i) Initial type testing to EN 1634-1 and EN 12209/EN 179 (where relevant)
 - ii) An appraisal against TS23 or TS31 (where relevant)
 - iii) Inspection of quality management system.
 - iv) Inspection and surveillance of factory production control
 - v) On-going audit testing in accordance with TS23 or TS31 requirements

Signed
C/014



Page 2 of 8

Issued: 27th July 2015
Reissued: 8th December 2025
Valid to: 2nd June 2026

CERTIFICATE No CF 5342

DORMAKABA UK LTD

dormakaba SVP MORTICE LOCKSETS

6. The mortice locks and/or latches should only be used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) with similar size locks and strikeplates. The critical aspects of the doorset construction are considered to be the material of the door frame, the leaf to frame clearance gaps and the lipping material. Attention should be paid to these details and these should not be amended from that previously fire tested. The following minimum specification shall be followed:

Timber-based assemblies:

- i) Door frame density - 450 kg/m³ (30 minutes), 640 kg/m³ (60 minutes)
 - ii) Door leaves shall have a minimum thickness of 44 mm for 30 minute applications and 54 mm for 60 minute applications.
 - iii) Lipping density - 640 kg/m³.
7. When fitted to insulated timber or mineral composite door assemblies, The required protection will be as follows:
- ii) The required protection for 30 minute ITT applications will be 1 mm thick Interdens mono ammonium phosphate intumescent sheet material around the lock case and behind the forend and strike plate.
 - iii) The required protection for 60 minute ITT applications will be 1 mm thick Interdens mono ammonium phosphate intumescent sheet material around the lock case and behind the forend and strike plate. Additionally the perimeter intumescent within the frame/door edge shall by-pass the strike plate or forend by a minimum of 10 mm wide on each side (with the exception of the latchbolt lead where present).

Failure to install the protection will invalidate this certificate

8. The locks should not be fitted higher than 1100 mm from the finished floor level of the surrounding floors.
9. Recessing for locks shall result in a tight fit, allowing for any intumescent protection where required. Mortices for the latchbolt and deadbolt behind the strikeplate shall be as small as possible.
10. The spindle hole through the door shall be a maximum of 15 mm diameter unless the doorset has test evidence that proves spindle holes of a greater size than this.

Signed
C/014



Page 3 of 8

Issued: 27th July 2015
Reissued: 8th December 2025
Valid to: 2nd June 2026



CERTIFICATE No CF 5342

DORMAKABA UK LTD

dormakaba SVP MORTICE LOCKSETS

11. The mortice locks may incorporate Euro profile cylinders as follows:

- i) Single cylinder
- ii) Double cylinder
- iii) Cylinder and thumbturn
- iv) Brass or steel cylinders for ITT30 and 60 doorsets

Note: The hole in the door face shall follow the shape of the cylinders and be as tight as possible; furthermore the single cylinders door preparation will penetrate through only half the thickness of the door leaf)

12. Where necessary the doorset shall have suitable supporting test evidence for any conduit and door loop required to connect the electrical lock elements.
13. The effectiveness and electrical safety of this electrically operated lock is outside the scope of this certification.
14. Those lock models approved for use as an emergency exit device by TS 31 "The Contribution Of Emergency Exit Devices, Operated By A Lever Handle Or Push Pad, To The Performance Of Fire Resisting Door Assemblies" are approved only when fitted to single leaf doorsets and only when fitted with the approved accessories detailed within the classifications section of this certificate.
15. Timber doorsets shall be installed in accordance with BS 8214.
16. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Signed
C/014

Page 4 of 8

Issued: 27th July 2015
Reissued: 8th December 2025
Valid to: 2nd June 2026

CERTIFICATE No CF 5342 DORMAKABA UK LTD

dormakaba SVP MORTICE LOCKSETS

17. The following table shows the acceptable doorset types and fire resistance periods:

Class	Approved Door Type				
	IMM	MM	ITT	ITM	ITC
FD20	x	x	✓	x	x
FD30	x	x	✓	x	x
FD60	x	x	✓*	x	x
FD90	x	x	x	x	x
FD120	x	x	x	x	x
FD240	x	x	x	x	x
E 20	x	x	✓	x	x
EI 20	x	x	✓	x	x
E 30	x	x	✓	x	x
EI 30	x	x	✓	x	x
E 60	x	x	✓*	x	x
EI 60	x	x	✓*	x	x
E 90	x	x	x	x	x
EI 90	x	x	x	x	x
E 120	x	x	x	x	x
EI 120	x	x	x	x	x
E 240	x	x	x	x	x
EI 240	x	x	x	x	x

Key:

- ✓ - approved
- x - Not approved
- ✓* - Excludes 'C-Lever Pro' handles/readers

Signed
C/014



Page 5 of 8

Issued: 27th July 2015
Reissued: 8th December 2025
Valid to: 2nd June 2026



CERTIFICATE No CF 5342 DORMAKABA UK LTD

dormakaba SVP MORTICE LOCKSETS

18. Doors are classified as the following types:

Code ITT - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in timber-based frames.

Code ITM - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in steel frames.

Code ITC - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

Code MM - 20 to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames without intumescent seals.

Code IMM - 20 to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames with intumescent seals.

Approved lock/latch models and classifications.

SVP 42xx, 43xx, 52xx and 53xx - EN 12209: 2003 (50-65 mm backsets only):

3	X	9	1	0	G	7	B	B	2	0
---	---	---	---	---	---	---	---	---	---	---

SVP 22XX, 23XX - EN 179: 2008 (50 - 65 mm backsets only):

3	7	7	B	1	4	5	2	A	B/D
---	---	---	---	---	---	---	---	---	-----

SVP 42XX, 43XX - EN 179: 2008 (50 - 65 mm backsets only):

3	7	7	B	1	4	5	2	A	B/D
---	---	---	---	---	---	---	---	---	-----

SVP 52XX, 53XX - EN 179: 2008 (50 - 65 mm backsets only):

3	7	7	B	1	4	5	2	A	B/D
---	---	---	---	---	---	---	---	---	-----

SVP 62XX, 63XX - EN 179: 2008 (50 - 65 mm backsets only)

3	7	7	B	1	4	5	2	A	B/D
---	---	---	---	---	---	---	---	---	-----

Signed
C/014

Page 6 of 8

Issued: 27th July 2015
Reissued: 8th December 2025
Valid to: 2nd June 2026



CERTIFICATE No CF 5342

DORMAKABA UK LTD

dormakaba SVP MORTICE LOCKSETS

Scope of approval

- The locks may not be fitted to timber/mineral-based doorsets without perimeter intumescent fire seals fitted with the frame rebate or door edge.
- ITT door leaves shall have solid lignocellulosic construction in the lock area encompassing the entire lock case.
- Strikeplates/keeps
 - The range of locks/latches is approved with a range of strikeplates/keeps. All of which are steel and the a maximum size permitted for use on all doorsets is as follows:

width	24 mm (exc. Lip)
height	232 mm
thickness	1.5 mm
Latchbolt- lip height	176 mm

- The use of the 'C-Lever Pro' handles/readers is restricted to a maximum of 30 minutes fire resistance.
- EN 179 classified locks are certified for use on single leaf doorsets only with the following accessories:

No.	manufacturer	coding
1	OGRO Beschlagtechnik GmbH	DO 20.4.01 DO 20.4.02
2	FSB	DO 20.3.01 DO 20.3.02
3	HEWI	VE 30-26
4	HOPPE	DO 20.7.01 DO 20.7.02 DO 20.20.01 DO 20.20.02
5	Grundmann	DO 20.26.01 DO 20.26.02
6	dormakaba Austria GmbH	DO 20.31.01 DO 20.31.02
7	SimonsVoss	DO 20.55.01
8	Glutz	
9	BKS	DO 20.10.01 DO 20.10.02
10	ECO	DO 20.1.01 DO 2.17.01 DO 25.21.01
11	Südmittel	ift 230 8008783-4-1
12	HAFI Beschläge GmbH	DO 20.32.01 DO 20.32.02
13	dormakaba Schweiz AG	DO 6.21

Signed
C/014

Page 7 of 8

Issued: 27th July 2015
Reissued: 8th December 2025
Valid to: 2nd June 2026



CERTIFICATE No CF 5342
DORMAKABA UK LTD

dormakaba SVP MORTICE LOCKSETS

Further Information

Further information regarding the details contained in this certificate may be obtained from DORMA UK Ltd (Tel: 01462 477600).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Signed
C/014

Page 8 of 8

Issued: 27th July 2015
Reissued: 8th December 2025
Valid to: 2nd June 2026